

	Minde gode varmeafledningsforhold		Normale varmeafledningsforhold		Særligt gode varmeafledningsforhold
Installationsmåder iht 523 tabel 52-D2	<a href="#">1</a> , <a href="#">3</a> , <a href="#">12</a> , <a href="#">15</a> , <a href="#">16</a>	<a href="#">2</a>	<a href="#">4</a> , <a href="#">6</a> , <a href="#">7</a> , <a href="#">10</a> , <a href="#">13</a> , <a href="#">20</a> , <a href="#">21</a> , <a href="#">30</a> , <a href="#">50</a> , <a href="#">51</a> , <a href="#">52</a> , <a href="#">53</a> , <a href="#">55</a> , <a href="#">56</a> , <a href="#">57</a> , <a href="#">58</a> , <a href="#">59</a> , <a href="#">60</a>	<a href="#">5</a> , <a href="#">8</a> , <a href="#">9</a> , <a href="#">11</a> , <a href="#">14</a> , <a href="#">40-47</a> , <a href="#">54</a>	<a href="#">22</a> , <a href="#">31</a> , <a href="#">32</a> , <a href="#">33</a> , <a href="#">34</a> , <a href="#">35</a> , <a href="#">36</a>
Ledertværsnit mm <sup>2</sup>	Strømværdier [A]				
<b>KOBBER</b>					
0,196	2	2	2,5	2,5	2,7
0,283	3	3	3,5	3,5	3,8
0,5	5	5	6	6	6,5
0,75	7,5	7,5	9	9	10
1	10,5	10,5	12	12	14,5
1,5	13,5	13	15,5	15	18,5
2,5	18	17,5	21	20	25
4	24	23	28	27	34
6	31	29	36	34	43
10	42	39	50	46	60
16	56	52	68	62	80
25	73	68	89	80	101
35	89	83	111	99	126
50	108	99	134	118	153
70	136	125	171	149	196
95	164	150	207	179	238
120	188	172	239	206	276
150	216	196	299	<a href="#">236</a>	319
185	248	223	341	<a href="#">268</a>	364
240	286	261	403	<a href="#">313</a>	430
300	328	298	464	<a href="#">358</a>	497